

PINE COVE WATER DISTRICT
OPERATIONS REPORT
October 12, 2016

1. Production:

A. July 2016	3,486,190 Gallons
July 2015	2,918,960 Gallons
July 2014	3,671,130 Gallons

All meters read and billed August 1:

Produced:	7,091,180 gallons
Accounted:	6,350,301 gallons
Loss:	10.5%

August 2016	3,818,950 gallons
August 2015	3,416,820 gallons
August 2014	3,725,220 gallons

September 2016	3,080,030 gallons
September 2015	2,598,260 gallons
September 2014	2,725,560 gallons

All meters read and billed October 1.

Produced:	6,898,980 gallons
Accounted:	5,955,910 gallons
Loss:	14%

- B. Static Well #10 –146' – Down 2 feet.
- C. Dutch Flats Wells.
- D. Well #24 – Not in operation.

2. Other Items:

- A. Weather Station, Website and Blog – Update.
- B. Pine Cove Rd. – 6" main with hydrants, completed and cost breakdown.
- C. Pine Cove complex – Progressing.
- D. Backyard – Electric gate, shed.
- E. SCE testing/Leak detection/Tank Inspection – scheduled..
- F. Rocky Pt Electronic Site – Update and needed changes/Comtronix Lease/Radio Club.
- G. Mutual Aid Agreement with FVWD & IWD.
- H. John Egan –Rates, Overall Plan - Update.
- I. Water Resources Board – System Inspection.
- J. Internet Service - Cameras

- K. Total Hydrants 182, steamers – 85, single 2 ½ - 97.
- L. BBVA Remote Deposit system – works great. New Credit Card Processor.
- M. Applying for Grants – still.
- N. PCWD to sponsor Brown Act, Ethics Refresher by Brad Neufeld.
- O. Field employee status.

Jerry Holldber, General Manager