

PINE COVE WATER DISTRICT  
OPERATIONS REPORT  
August 14, 2024

1. Production:

A. July 2024	3,504,049 Gallons
July 2023	3,181,072 Gallons
July 2022	4,180,830 Gallons
B. 2-month production (June/July)	6,712,820 Gallons
Accounted for	5,940,734 Gallons
Water loss	11%
C. Static Well #10 – 60.52 feet	
Up 1/10 <sup>th</sup> feet	

2. Other Items:

- a. Meter Installations – Continuing with the installation – Crews are on route 6 of 7. We are still on target to finish at the end of September.
- b. Production Sources – Well #25 has been refurbished, tested, and back online – producing an average of 40 gpm. The same procedure will be done to Well #26 also in the Dutch Flats area.
- c. Staffing/HR – Kaley has asked and shown interest in becoming water operator certified D1, T1.

---

Jeremy Potter, General Manager